

# **Dual Solenoid SCADA**and Position Controls

Flexible, direct, electronic control for use with SCADA, telemetered systems, IoT, modulating control, and local control.



TECHNICAL GUIDE: AVH1.15

## **Applications**

Potable water

Pressure systems

Municipal

Mining Applications

Irrigation Applications

# **Product Attributes**

Precise control from remote locations

Telemetry controller compatible

Minimal power needed for stand-by operation

Complete service in-line

Manual controls for emergencies

SCADA compatible

# Quality


AS 5081:2008

Flanging to AS/NZS 4087

Coating to AS/NZS 4158



The Singer dual solenoid electronic valves are based on the Singer model 106-PG or 206-PG main valve.



The flow into and out of the upper operating chamber is controlled by the two pilot solenoids. The electronic control determines whether the opening solenoid or the closing solenoid is operated. The change in valve position is dependent upon which solenoid is operated and the duration of the energized period. The electronic control determines the valve function. Virtually any hydraulic function can be achieved using the "open-close" output from the SCADA controller to the valve.

The Singer Model 2SC-PCO is designed for use with Singer MCP Multi-Process Control Panel or the EPC Single-Process Control Panel.

### **STANDARD MATERIALS**

Standard materials for pilot system components are:

- ASTM B-16 brass
- AISI 316 or 18-8 stainless steel trim
- NEMA 4X rated solenoid coils


#### **TYPICAL APPLICATION**

The two pilot solenoids are operated to keep two independent signals matched. In this case, the valve is operated to ensure the "process variable signal" follows the "SCADA set-point command signal".

Typically this mode is used when the process variable signal is from a flow meter, pressure sensor or similarly quick changing process. This is referred to as "set-point control".

#### **SELECTION SUMMARY**

- 1. Select a valve with sufficient capacity, using the allowable operating pressure drop across the valve.
- 2. Usually operating in the continuous, "C", service range up to 20 ft /s / 6 m / s
- 3. If the outlet pressure is less than 35% of the inlet pressure, check for cavitation.
- 4. Ensure the max working pressure rating of the valve exceeds the max operating pressure.
- 5. Ensure the solenoid coils are compatible with the electronic controllers 120 VAC / 60 Hz standard.
- 6. Verify that the electronic controls are properly configured to provide the functions required.
  - a. for compatible electronic controls, refer to Singer Process Control Panels
  - b. for applications requiring high pressure drops, refer to Singer model 106-AC
  - c. standard hydraulic pilots can provide back-up control should the system go off limits
  - d. for applications where electric service and electronic controls are unsuitable, refer to the standard hydraulic model
  - addition of Position Transmitter and Differential Pressure Transmitter or SPI-MV are required for metering function.



## **SCHEMATIC DRAWING**

- 1. Main Valve 106-PG or 206-PG
- 2. Isolating Valves (2A, 2B, 2C)
- 3. Strainer 40 mesh stainless steel screen
- 4. Closing Speed Control micrometer needle valve
- Closing Solenoid Pilot Valve -120 VAC / 60 Hz standard, other voltages available
- Opening Solenoid Pilot Valve -120 VAC / 60 Hz standard, other voltages available
- 7. Manual Closing Bypass
- 8. Manual Opening Bypass
- Opening Speed Control micrometer needle valve
- 10. Optional X156 Analog Position Transmitter (4 to 20 mA)

\*Note\*: All 106 series 21/2 in / 65 mm to 4 in / 100 mm and all 206 series 4 in / 100 mm to 6 in / 150 mm will be fitted with heavy springs.

**Note:** SRD shown is available for 6" 106-PG and larger.

| 106-2SC-PCO<br>Size (inches)            | Flow Capacity (See 106-PG in Main Valve section for other valve data) |       |        |        |        |        |        |        |        |        |        |        |  |  |  |
|---|---|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--|--|--|
|   | $2^{1}/_{2}$ in   | 3 in  | 4 in   | 6 in   | 8 in   | 10 in  | 12 in  | 14 in  | 16 in  | 20 in  | 24 in  | 36 in  |  |  |  |
| Size ( mm)                              | 65 mm   | 80 mm | 100 mm | 150 mm | 200 mm | 250 mm | 300 mm | 350 mm | 400 mm | 500 mm | 600 mm | 900 mm |  |  |  |
| Minimum<br>(USGPM)<br>Flat Diaphragm    | CF  | CF    | 10     | 20     | 40     | -      | -      | -      | -      | -      | -      | -      |  |  |  |
| Minimum<br>(USGPM)<br>Rolling Diaphragm | -   | -     | -      | 1      | 1      | 3      | 3      | 3      | 3      | 10     | 10     | 20     |  |  |  |
| Minimum (L/s)<br>Flat Diaphragm         | CF  | CF    | 0.63   | 1.26   | 2.52   | -      | -      | -      | -      | -      | -      | -      |  |  |  |
| Minimum (L/s)<br>Rolling Diaphragm      | -   | -     | -      | 0.1    | 0.1    | 0.2    | 0.2    | 0.2    | 0.2    | 0.6    | 0.6    | 1.3    |  |  |  |
| Maximum<br>Continuous<br>(USGPM)        | CF  | CF    | 800    | 1800   | 3100   | 4900   | 7000   | 8500   | 11000  | 17500  | 25000  | 55470  |  |  |  |
| Maximum<br>Continuous<br>(L/s)          | CF  | CF    | 50     | 114    | 196    | 309    | 442    | 536    | 694    | 1104   | 1577   | 3500   |  |  |  |

| 206-2SC-<br>PCO<br>Size (inches)           | Flow     | Flow Capacity (See 206-PG in Main Valve section for other valve data) |           |           |           |           |           |           |           |                    |                    |           |           |           |           |            |
|--|----------|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|--------------------|--------------------|-----------|-----------|-----------|-----------|------------|
|  | 3 in     | 4 in  | 6 in      | 8 in      | 10 in     | 12 in     | 16 in     | 18 in     | 20 in     | 24 x<br>16 in      | 24 x<br>20<br>in   | 28 in     | 30 in     | 32 in     | 36 in     | 40 in      |
| Size ( mm)                                 | 80<br>mm | 100<br>mm   | 150<br>mm | 200<br>mm | 250<br>mm | 300<br>mm | 400<br>mm | 450<br>mm | 500<br>mm | 600<br>X 400<br>mm | 600<br>x 500<br>mm | 700<br>mm | 750<br>mm | 800<br>mm | 900<br>mm | 1000<br>mm |
| Minimum<br>(USGPM)<br>Flat<br>Diaphragm    | CF       | 5   | 10        | 20        | 40        | -         | -         | -         | -         | -                  | -                  | -         | -         | -         | -         | -          |
| Minimum<br>(USGPM)<br>Rolling<br>Diaphragm | -        | -   | -         | -         | -         | 3         | 3         | 3         | 3         | 3                  | 10                 | 10        | 10        | 10        | 10        | 20         |
| Minimum<br>(L/s)<br>Flat<br>Diaphragm      | CF       | 0.3   | 0.6       | 1.3       | 2.5       | -         | -         | -         | -         | -                  | -                  | -         | -         | -         | -         | -          |
| Minimum (L/s) Rolling Diaphragm            | -        | -   | -         | -         | -         | 0.19      | 0.19      | 0.19      | 0.19      | 0.19               | 0.19               | 0.63      | 0.63      | 0.63      | 0.63      | 1.3        |
| Maximum<br>Continuous<br>(USGPM)           | CF       | 580   | 1025      | 2300      | 4100      | 6400      | 9230      | 16500     | 16500     | 1600               | 21700              | 33600     | 33650     | 33700     | 33800     | 62000      |
| Maximum<br>Continuous<br>(L/s)             | CF       | 37  | 65        | 145       | 260       | 404       | 582       | 1040      | 1040      | 1040               | 1370               | 2120      | 2123      | 2126      | 2132      | 3912       |

Note: CF = Consult Hygrade on all sizes 3" (80 mm) and under



Scan for more information

**Disclaimer**: While every effort has been made to ensure that the information in this document is correct and accurate, users of Hygrade Water Infrastructure product or information within this document must make their own assessment of suitability for their particular application. Product drimensions are nominal only, and should be verified if critical to a particular installation. No warrantly is either expressed, implied, or statutory made by Hygrade Water Infrastructure unless expressly stated in any sale and purchase agreement entered into between Hygrade Water Infrastructure and the user. **July 2024** 

